

**ADDENDUM TO FACT SHEET**  
**Permit No. WA-003088-1**  
**MARCO Shipyard Seattle**  
**February 27, 2004**

This is an addendum to the fact sheet accompanying NPDES Permit No. WA-003088-1, which was issued to MARCO Shipyard Seattle on December 17, 2002. The following revision is made as a result of a recent change of the wastewater treatment system by MARCO.

**PROPOSED MODIFICATION FOR THE PERMIT**

Special Condition S1.A., on page 5 of the permit: The first paragraph will be deleted to reflect the recently constructed treatment system at the shipyard. The “Interim Effluent Limitations” table will also be deleted.

Special Condition S1.B., Section B. Stormwater Discharges shall also be changed on page 6 of the permit:

Beginning December 11, 2003, and lasting through the expiration date, all industrial stormwater discharges to Lake Washington Ship Canal are prohibited except when precipitation exceeds the design storm. Any diversion ditch or channel constructed at the site for routing of industrial stormwater shall be designed, constructed, and maintained to contain all flow except when precipitation exceeds the design storm. The design storm is the maximum volume of water resulting from the 5-year, 24-hour precipitation event. During periods exceeding the design storm, the Permittee is authorized to discharge industrial stormwater at the permitted location subject to complying with the following limitations:

**Limits for Stormwater Overflow**

Parameters	Oil & Grease	Turbidity	Copper (TR)	Lead (TR)	Zinc (TR)
Overflow	5 mg/l	5 over background	6.2 µg/l	19.6 µg/l	45.8 µg/l

All current information in that section shall be deleted and replaced with the following: “As of February 27, 2004, of this permit, all stormwater discharges up to and including the 5-year, 24-hour engineered design shall be prohibited from overflowing from MARCO. Discharges greater than the 5-year, 24-hour design storm shall be authorized; however, each event shall be monitored as required in Special Condition S2.B. and storm event information, such as inches of rainfall and date, shall be submitted with the required monitoring reports.”

Special Condition S2.B., on page 7 of the permit, will be changed from monitoring the outfalls to monitoring the overflows and a note will be inserted stating stormwater discharge has been eliminated. “As of December 11, 2003, all stormwater is routed to the King County Wastewater Treatment Plant.”

## **PUBLIC NOTICES**

The proposed changes to this permit are considered to constitute a minor modification under 40 CFR 122.63. “Upon the consent of the permittee, the Director may modify a permit to make the corrections or allowances for changes in the permitted activity listed in this section, without following the procedures of part 124. Any permit modification not processed as a minor modification under this section must be made for cause and with part 124 draft permit and public notice as required in § 122.62. Minor modifications may only: ...

... (2) Delete a point source outfall when the discharge from that outfall is terminated and does not result in discharge of pollutants from other outfalls except in accordance with permit limits.” Consequently, the draft permit modification is not required to be published.